

BUILDING SAFETY CERTIFICATE

No. 125/2026

Dated: 27.02.2026

It is certified that the existing building of **GHANASHYAM HEMALATA VIDYAMANDIR, PURI** (name of the building or premises) at **R.J. Vihar, Chhaitana, Bhuan, Puri, 752004, Odisha** is having block(s) / Floor(s) as per details below:


Details of Block(s) in School	Block (1)
No. of Floor(s) in the Block	G + 2

The building is owned / occupied by **GHANASHYAM HEMALATA VIDYAMANDIR, PURI** have complied with the Building Safety requirements in accordance with National Building Code Rules, and verified by the officers concerned of **R & B Department, Konark, Govt. of Odisha** on 25.02.2026 (Date of inspection) in the presence of **Mr. Aswini Kumar Palo, Principal, GHANASHYAM HEMALATA VIDYAMANDIR, R.J. VIHAR, CHHAITANA, BHUAN, PURI, 752004** (Name & Address of the Manager / Secretary or his representative) and that the building / premises is fit for occupancy for running school with effect from 27.02.2026 for a period of 3 (three) years in accordance with rule and subject to compliance of the specific conditions as appended.

1. Ramp & Railing provided for physically handicapped students.
2. Stair case width is **1.50 mtr.** Rise of steps is **0.15 mtr**, tread is **0.30 mtr.**
3. Ceiling height from floor measured and it is **3.45 mtr.**
4. Paved roads available for movement of fire engine around building.

Issued on 27.02.2026 at **Konark** by

- Strike out whichever is not applicable. In case of blocks is more than six use separate sheet for detail.

Signature with seal: 
27/02/2026

Name: Officer by J313 W.C.I.

Designation: Asst. Executive Engineer

Assistant Executive Engineer
Konark (R&B) Section


PRINCIPAL
Ghanashyam Hemalata
Vidyamandir
Puri-2


Manager
Ghanashyam Hemalata
Vidyamandir, Puri